

**CUE DATA REQUEST**  
**CUE-SEU-DR-07**  
**UTILITIES 2019 GRC – A.17-10-008**  
**SOCALGAS RESPONSE**  
**DATE RECEIVED: FEBRUARY 20, 2018**  
**DATE RESPONDED: MARCH 8, 2018**

276. With regards to the spreadsheet "OHConductorAgeMiles.xlsx" provided in response to CUE Data Request 147:

- a. Please confirm that SDG&E does not know the age of three-fourths of its overhead conductor (4850 miles out of 6495 miles)
- b. Please explain (and correct if necessary) the double entries for 1929 and 1947, which have different footage for each entry
- c. Please explain (and correct if necessary) the double entry for 1950, which has the same footage for each entry
- d. Please explain (and correct if necessary) the adjacent entries, with different footage, for 1959 and "1059".

**SDG&E's Response 276:**

- a. That is correct. While SDG&E's electric facilities database has improved the quality of records during recent years, it does not contain the same level of detail for older vintage facilities, including overhead conductor.
- b. Correction made, please see new document "OHConductorAgeMiles\_CUE007.xlsx" the data should read once for 1929 with 441 and remove double entry for 1947.
- c. Correction made, please see new document "OHConductorAgeMiles\_CUE007.xlsx" the data should read once for 1950
- d. Correction made, please see new document "OHConductorAgeMiles\_CUE007.xlsx" the data should read once for 1959