

TEST PRESSURE - 1260 PSIG (ASSUMING ~~1260~~ PSIG HYDROSTATIC HEAD)

First 2 hrs / test every 10 min.

Afterwards, for next 6 hrs / every 20 min

3879.015 3900

L-306 HYDROTEST

6/10/84

TEST PRESSURE DATA @ MP 43.30

~~FOR~~ ^{M.P.} 43.30

MP 41.26

~~BOTTOM~~

Started 12:20

REAL TIME (HRS. / MIN.)	ELAPSED TIME (MIN.)	WATER PRESSURE (PSIG)	WATER TEMP. (°F)	WATER PRESS PSIG	
(1196) 1:11	0	1260	86°	1190	96°
shut down to replace fitting 1:21	10	1265	85°	1185	82°
1:31	20	1274	84°	1195	80°
1:41	30	1273	84°	1195	80°
1:51	40	1273	82°	1195	82°
2:01	50	1273	81°	1194	82°
2:11	60	1273	80°	1194	82°
2:21	70	1274	81°	1194	82°
2:31	80	1274	84°	1194	82°
2:41	90	1274	86°	1194	80°
2:51	100	1274	88°	1193	11
3:01	110	1274	86°	1193	11
3:11	120	1272	86°	1193	80°
3:31	140	1274	90°	1193	81°
3:51	160	1274	90°	1192	80°
3 HRS 4:11	180	1272	86°	1192	83°
4:31	200	1271	85°	1190	80
4:51	220	1272	80°	1190	80°
4 5:11	240	1271	77°	1189	82